

AGENCY OF NATURAL RESOURCES

Waterbury, Vermont

ENVIRONMENTAL PROTECTION REGULATIONS

CHAPTER 5

AIR POLLUTION CONTROL

Subchapter II. Prohibitions

Section 5-252 Control of Sulfur Dioxide Emissions

- (1) No person shall discharge, or cause, allow or permit emissions of sulfur dioxide from a stationary combustion installation with a heat input capacity of 250 million BTU's per hour or more in excess of:
 - (a) 1.4 grams per million calories heat input (0.80 pounds per million BTU) derived from liquid fossil fuel.
 - (b) 2.2 grams per million calories heat input (1.2 pounds per million BTU) derived from solid fossil fuel.
- (2) This limit shall not apply to gas turbine generators.